



Typical Injection Wellhead Assembly and Meter Run

ADAPTED FROM THE API INJECTION WELL HANDBOOK
 ALL ITEMS OPTIONAL LESS PRESSURE TAPS

- A - concrete unloading pad with concrete vault.
- B - Impermeable dike of sufficient capacity to contain volume of largest tank on site.
- C - Containment vessels
- D - In-line filter system
- E - Pump
- F - Injection well

Note: All facilities must contain as a minimum items A, B, C and F.

